

POINT OF DELIVERY LOCATION

METER BASE LOCATION IS AN IMPORTANT CONSIDERATION TO BOTH THE COOPERATIVE AND THE MEMBER.

- (A) OVERHEAD OR UNDERGROUND FACILITIES
- (B) SERVICE WIRE SHALL NOT BE OVER OR UNDER BUILDINGS (RESIDENTIAL, COMMERCIAL BUILDINGS, ETC.)
- (C) METER BASE
 - (1) REQUESTED LOCATION TO BE ACCESSIBLE TO M.V.E.C. PERSONNEL
 - (2) ALTERNATE LOCATION IN THE SHADED AREA UNDER OVERHANG
 - (3) BAD LOCATION FOR METER DUE TO TREE IN THE PATH OF SERVICE WIRE
 - (4) MEMBER DISCONNECT REQUESTED LOCATION

NOTE:

ADDITIONAL POLE MAY BE NEEDED IF METER LOCATION IS FURTHER THAN 80 FEET FROM OVERHEAD FACILITIES

- (D) TREES
AVOID TREES IN OR UNDER PATH FROM THE SERVICE WIRE
- (E) SEPTIC TANKS
IDENTIFY LOCATION OF BURIED SEPTIC TANKS FOR THE SAFETY OF M.V.E.C. PERSONNEL AND PREVENTION OF VEHICLE DAMAGE TO THE SEPTIC TANKS AND LINES

